

**Interpretation to BPI Technical Standards  
for the Building Analyst Professional v.1-4-12  
Unvented Appliances**

Question: Does the reference to unvented combustion appliances in the *Building Analyst Professional* standard, p.14, apply to unvented alcohol-fueled appliances?

Answer: Yes, the reference applies regardless of fuel source.